

# General Environmental Incident Summary

**Incident:** 3829      **Date/Time Notice:** 7/22/2015      **DEM Incident No:**

**Responsible Party:** MDM Construction

**Date Incident:** 7/21/2015      **Time Incident:** 1900      **Duration:**

**County:** Cass      **Twp:** 140      **Rng:** 48      **Sec:** 30      **Qtr:** NW

**Lat:** 46.90687      **Long:** -96.77681      **Method:** Interpolation from map

**Location Description:** Fargo VA Health Care System  
2101 Elm Street North  
Fargo ND, 58102

**Submitted By:** John Englund

**Affiliation:** Fargo VA HCS

**Address:** 2101 Elm Street North

Mail Code 138S

**City:** Fargo

**State:** ND

**Zip:** 58102

## Received By:

**Contact Person:** Dan Walters  
45 21st Avenue East  
Suite F  
West Fargo, ND 58078

**Distance Nearest Occupied Building:** 10 Feet

**Release Contained:** Yes

**Type of Incident:** Coolant pipe break

**Description of Released Contaminant:** Water mixed with 30%-50% Propylene Glycol

**Volume Spilled:**

**Ag Related:** No

**EPA Extremely Hazardous Substance:** No

**Reported to NRC:** Unknown

## Cause of Incident:

A coolant line was accidentally hit and broken during excavation.

## Risk Evaluation:

None

**# of Fatalities:** 0

**# of Injuries:** 0

**Affected Medium:** 03 - soil

## Potential Environmental Impacts:

None expected

## Action Taken or Planned:

The spill was contained in the excavation pit.

**Wastes Disposal Location:** The propylene glycol soaked into the ground. A soil sample will be taken and we are working with the local public health unit.

***Agencies Involved:***

***Updates***

---

***Date:*** 7/23/2015    ***Status:*** Reviewed - No Action Required

***Author:*** Crowdus, Kory

***Updated Volume:***

***Notes:***

Release contained, no follow-up required.